



DECLARATION OF PERFORMANCE

No: DoP 705/2015_5_EN

1. Unique identification code of the product-type:	Rectangular fire damper
2. Identification of the construction product:	FD 40
3. Intended use(s) of the construction product:	Rectangular fire damper to be used in conjunction with fire separating elements to maintain fire compartments in HVAC installations.
4. Name and contact address of the manufacturer:	Klimaoprema d.d., Gradna 78A, 10430 Samobor
5. Not applicable	
6. System of assessment and verification of constancy of performance of the construction product	System 1
7. In case of the declaration of performance concerning a construction product covered by a harmonised standard:	The notified body 1396 carried out the initial inspection of the manufacturing plant and of the factory production control as well as the continuous surveillance, assessment and evaluation of factory production control under system 1 and issued the Certificate of constancy of performance 1396-CPR-0073
8. Not applicable	
9. Declared performance according to EN 15650:	(Fire resistance according to EN 1366-2 and classifications according to EN 13501-3)

Essential characteristics			Performance	
Range	Supporting construction	Supporting construction details	Classification	
200x200 mm up to 1500x800 mm	Rigid wall	Aerated concrete ≥100mm	Gypsum plaster/Mortar/Concrete	
			Mineral wool ≥140 kg/m ³ + fire resistant coating	
			Remote from wall	
	Flexible wall	Metal studs wall, gypsum plasterboard GKB, GKF with mineral wool ≥100mm	Metal studs wall, gypsum plasterboard GKF with mineral wool ≥100mm	Gypsum plaster/Mortar/Concrete with cover slabs
				Mineral wool ≥140 kg/m ³ + fire resistant coating
				Mineral wool ≥140 kg/m ³ + fire resistant coating
				Mineral wool ≥140 kg/m ³ + fire resistant coating
	Floor/ceiling	Reinforced concrete ≥150mm	Reinforced concrete ≥150mm	Gypsum plaster/Mortar/Concrete with cover slabs
				Gypsum plaster/Mortar/Concrete
				Mineral wool ≥140 kg/m ³ + fire resistant coating
Type of installation: built in, 0-90-180-270°		Type of installation: remote from wall, 0-180°		
				
Nominal activation conditions/sensitivity according to ISO 10294-4: - sensing element load bearing capacity - sensing element response temperature			Passed	
Response delay (closing time) according to EN 1366-2:			Passed	
Operational reliability (opening, closing) according to EN 1366-2:			Passed	
Durability of response delay according to ISO 10294-4: - sensing element response to temperature and load bearing capacity			Passed	
Durability of operational reliability (opening and closing cycle) according to EN 15650: - Belimo B(L)F-T-(ST), BFL-T/BFN-T, Siemens GNA/GGA, Schischek ExMax 5.10 - 10 000 cycles			Passed	
Protection against corrosion according to EN 60068-2-52:			NPD	
Damper blade and casing leakage according to EN 1751:			Class ≥ A	

Harmonised standard EN 15650:2010

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 7.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for on behalf of the manufacturer by:

Branko Duvnjak, General manager



Samobor, 8. May 2015

